

# Detailed Latest Test Results



Test Status: All, Test Type: All

Asset ID	Description	Make	Test Type	HOME	Date Tested	Next Test	AMAZINGSTEPHEN
116	AMP	TRIO	Insulation Resistance	MOhm> 199	07/07/2009	07/07/2010	Pass
117	DVD	TOSHIBA	Insulation Resistance	MOhm> 199	07/07/2009	07/07/2010	Pass
118	SC4000E	SOUNDCHASER	Earth Continuity	ohm0.08	07/07/2009	07/07/2010	Pass
118	SC4000E	SOUNDCHASER	Insulation Resistance	MOhm> 199	07/07/2009	07/07/2010	Pass
120	AMP	HOHNER	Earth Continuity	ohm0.092	07/07/2009	07/07/2010	Pass
120	AMP	HOHNER	Insulation Resistance	MOhm> 199	07/07/2009	07/07/2010	Pass
121	STEREO	JVC	Insulation Resistance	MOhm> 199	07/07/2009	07/07/2010	Pass
122	EXTENSION LEAD		IEC Lead Continuity	ohm0.15	07/07/2009	07/07/2010	Pass
122	EXTENSION LEAD		Insulation Resistance	MOhm> 199	07/07/2009	07/07/2010	Pass
122	EXTENSION LEAD		IEC Lead Polarity		07/07/2009	07/07/2010	Pass

Total 6